

Arnold Irrigation District (AID)  
Patron Communication  
June 4th, 2025

Last night at 12:19 a.m. there was a power failure at the AID office. As a result of the power failure the telemetry equipment at the office closed the butterfly valve at Horse Butte. Subsequently water levels on the East side of the district declined rapidly.

This morning power is back on, the butterfly valve has been opened, and water is once again flowing on the East side of the district. Patrons may notice some fluctuations in water levels as normal flows are restored.

We will keep you advised if there are any further developments.